

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Outfall No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	0.0688	x	322	x	8.34	=	185
February	0.0677	x	301	x	8.34	=	170
March	0.0716	x	257	x	8.34	=	154
April	0.0661	x	297	x	8.34	=	164
May	0.0652	x	344	x	8.34	=	187
June	0.0631	x	287	x	8.34	=	151
July	0.0642	x	253	x	8.34	=	135
August	0.0619	x	251	x	8.34	=	130
September	0.0660	x	261	x	8.34	=	144
October	0.0615	x	275	x	8.34	=	141
November	0.0640	x	293	x	8.34	=	156
December	0.0643	x	332	x	8.34	=	178

2. Maximum Month Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.116	x	90	=	0.1044
		x	100	=	.116
Design (C)BOD, lbs/day	290	x	90	=	261
		x	100	=	290

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes gallons

No

Holding Tanks

Yes gallons

No

Grease Traps

Yes gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Yes

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

<ul style="list-style-type: none">● No <p>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	15	13.5	11	1	0	0
February	15	13.5	10	1	0	0
March	15	13.5	16	1	1	1
April	15	13.5	10	1	0	0
May	15	13.5	5	1	0	0
June	15	13.5	3	1	0	0
July	15	13.5	3	1	0	0
August	15	13.5	7	1	0	0
September	15	13.5	9	1	0	0
October	15	13.5	7	1	0	0
November	15	13.5	8	1	0	0
December	15	13.5	7	1	0	0
* Equals limit if limit is <= 10						
Months of discharge/yr				12		
Points per each exceedance with 12 months of discharge					7	3
Exceedances					1	1
Points					7	3
Total number of points						10

10

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

During the cold weather months and low flows at are plant it can be struggle to run. We have been working with our engineer Strand and Aqu Fix with possible causes and solutions. We are pretty much 99% residential waste and when small amount of toxic are dumped on us this may be causing our up sets. We have had some very high influent BOD/SS samples. We have reached out and started public education.

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

- Yes Enter last calibration date (MM/DD/YYYY)
- No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

During the cold weather months and low flows at are plant it can be struggle to run. We have been working with our engineer Strand and Aqu Fix with possible causes and solutions. We are pretty much 99% residential waste and when small amount of toxic are dumped on us this may be causing our up sets. We have had some very high influent BOD/SS samples. We have reached out and started public education.

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

If Yes, please explain:

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?

Yes

No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?

Yes

No

N/A

Please explain unless not applicable:

Total Points Generated	10
Score (100 - Total Points Generated)	90
Section Grade	B

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	20	18	18	1	0	1
February	20	18	14	1	0	0
March	20	18	17	1	0	0
April	20	18	12	1	0	0
May	20	18	4	1	0	0
June	20	18	3	1	0	0
July	20	18	4	1	0	0
August	20	18	6	1	0	0
September	20	18	10	1	0	0
October	20	18	7	1	0	0
November	20	18	14	1	0	0
December	20	18	10	1	0	0
* Equals limit if limit is <= 10						
Months of Discharge/yr				12		
Points per each exceedance with 12 months of discharge:					7	3
Exceedances					0	1
Points					0	3
Total Number of Points						3

3

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

During the cold weather months and low flows at are plant it can be struggle to run. We have been working with our engineer Strand and Aqu Fix with possible causes and solutions. We are pretty much 99% residential waste and when small amount of toxic are dumped on us this may be causing our up sets. We have had some very high influent BOD/SS samples. We have reached out and started public education.

Total Points Generated	3
Score (100 - Total Points Generated)	97
Section Grade	A

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for NH3

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	6.5		.100833333	0					
February	6.5		.105	0					
March	6.5		.12	0					
April	6.9		.087857143	0					
May	3.7		.104166667	0					
June	3.7		.103076923	0					
July	3.7		.222857143	0					
August	3.7		.4225	0					
September	3.7		.607142857	0					
October	3.7		.256923077	0					
November	6.5		.045454545	0					
December	6.5		.058571429	0					
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to detect exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to detect exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	7.9	4.5	1	0
February	7.9	4.5	1	0
March	7.9	5.3	1	0
April	7.9	4.0	1	0
May	7.9	6.3	1	0
June	7.9	7.5	1	0
July	7.9	8.9	1	1
August	7.9	8.5	1	1
September	7.9	9.2	1	1
October	7.9	7.4	1	0
November	7.9	6.1	1	0
December	7.9	4.4	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				3
Total Number of Points				30

30

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Phosphorus compliance planning, currently underway, will determine the need for any capital upgrades in the specified timeframe. In the preliminary compliance alternatives plan, we are looking at implementing biological and chemical phosphorus removal within the next five to ten years. Along with trades.

Total Points Generated	30
Score (100 - Total Points Generated)	70
Section Grade	D

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 003 - SLUDGE

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75									6.1					0	0
Cadmium		39	85									.82					0	0
Copper		1500	4300									971					0	0
Lead		300	840									24.1					0	0
Mercury		17	57									.34					0	0
Molybdenum	60		75									7.5				0		0
Nickel	336		420									7.6				0		0
Selenium	80		100									<5.1				0		0
Zinc		2800	7500									571					0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)

- N/A - Did not exceed limits or no HQ limit applies (0 points)
- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

<p>3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?</p> <input type="text"/>	0
<p>6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site? <ul style="list-style-type: none"> <input checked="" type="radio"/> >= 180 days (0 Points) <input type="radio"/> 150 - 179 days (10 Points) <input type="radio"/> 120 - 149 days (20 Points) <input type="radio"/> 90 - 119 days (30 Points) <input type="radio"/> < 90 days (40 Points) <input type="radio"/> N/A (0 Points) 6.2 If you checked N/A above, explain why.</p> <input type="text"/>	0
<p>7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <input type="text"/>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes (Continue with question 2)<input type="radio"/> No (40 points) <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<ul style="list-style-type: none"><input type="radio"/> Paper file system<input type="radio"/> Computer system<input checked="" type="radio"/> Both paper and computer system<input type="radio"/> No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M Manual that can be used as a reference when needed?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><input type="radio"/> Excellent<input checked="" type="radio"/> Very good<input type="radio"/> Good<input type="radio"/> Fair<input type="radio"/> Poor <p>Describe your rating:</p> <div style="border: 1px solid black; padding: 5px;">We have a good maintenance program in place.</div>	

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Operator Certification and Education

<p>1. Operator-In-Charge</p> <p>1.1 Did you have a designated operator-in-charge during the report year?</p> <ul style="list-style-type: none"> ● Yes (0 points) ○ No (20 points) <p>Name: <input style="width: 150px;" type="text" value="LEIF T SPILDE"/></p> <p>Certification No: <input style="width: 150px;" type="text" value="23236"/></p>	0																																																																																								
<p>2. Certification Requirements</p> <p>2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2">Sub Class</th> <th rowspan="2">SubClass Description</th> <th colspan="2">WWTP</th> <th colspan="2">OIC</th> </tr> <tr> <th>Basic</th> <th>OIT</th> <th>Basic</th> <th>Advanced</th> </tr> </thead> <tbody> <tr><td>A1</td><td>Suspended Growth Processes</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>A2</td><td>Attached Growth Processes</td><td></td><td></td><td></td><td></td></tr> <tr><td>A3</td><td>Recirculating Media Filters</td><td></td><td></td><td></td><td></td></tr> <tr><td>A4</td><td>Ponds, Lagoons and Natural</td><td></td><td></td><td></td><td></td></tr> <tr><td>A5</td><td>Anaerobic Treatment Of Liquid</td><td></td><td></td><td></td><td></td></tr> <tr><td>B</td><td>Solids Separation</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>C</td><td>Biological Solids/Sludges</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>P</td><td>Total Phosphorus</td><td></td><td>X</td><td></td><td></td></tr> <tr><td>N</td><td>Total Nitrogen</td><td></td><td></td><td></td><td></td></tr> <tr><td>D</td><td>Disinfection</td><td></td><td></td><td></td><td></td></tr> <tr><td>L</td><td>Laboratory</td><td></td><td></td><td>X</td><td></td></tr> <tr><td>U</td><td>Unique Treatment Systems</td><td></td><td></td><td></td><td></td></tr> <tr><td>SS</td><td>Sanitary Sewage Collection</td><td>X</td><td>NA</td><td>NA</td><td>NA</td></tr> </tbody> </table> <p>2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS, N and A5 not required in 2015 - 2016; subclass SS is basic level only.)</p> <ul style="list-style-type: none"> ● Yes (0 points) ○ No (20 points) 	Sub Class	SubClass Description	WWTP		OIC		Basic	OIT	Basic	Advanced	A1	Suspended Growth Processes	X		X		A2	Attached Growth Processes					A3	Recirculating Media Filters					A4	Ponds, Lagoons and Natural					A5	Anaerobic Treatment Of Liquid					B	Solids Separation	X		X		C	Biological Solids/Sludges	X		X		P	Total Phosphorus		X			N	Total Nitrogen					D	Disinfection					L	Laboratory			X		U	Unique Treatment Systems					SS	Sanitary Sewage Collection	X	NA	NA	NA	0
Sub Class			SubClass Description	WWTP		OIC																																																																																			
	Basic	OIT		Basic	Advanced																																																																																				
A1	Suspended Growth Processes	X		X																																																																																					
A2	Attached Growth Processes																																																																																								
A3	Recirculating Media Filters																																																																																								
A4	Ponds, Lagoons and Natural																																																																																								
A5	Anaerobic Treatment Of Liquid																																																																																								
B	Solids Separation	X		X																																																																																					
C	Biological Solids/Sludges	X		X																																																																																					
P	Total Phosphorus		X																																																																																						
N	Total Nitrogen																																																																																								
D	Disinfection																																																																																								
L	Laboratory			X																																																																																					
U	Unique Treatment Systems																																																																																								
SS	Sanitary Sewage Collection	X	NA	NA	NA																																																																																				
<p>3. Succession Planning</p> <p>3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> One or more additional certified operators on staff <input type="checkbox"/> An arrangement with another certified operator <input type="checkbox"/> An arrangement with another community with a certified operator <input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year <input type="checkbox"/> A consultant to serve as your certified operator <input type="checkbox"/> None of the above (20 points) <p>If "None of the above" is selected, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0																																																																																								
<p>4. Continuing Education Credits</p> <p>4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?</p> <p>OIT and Basic Certification:</p>																																																																																									

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

<ul style="list-style-type: none">● Averaging 6 or more CECs per year.○ Averaging less than 6 CECs per year. Advanced Certification: <ul style="list-style-type: none">○ Averaging 8 or more CECs per year.○ Averaging less than 8 CECs per year.	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 150px;" type="text" value="Carol Strause"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="608-455-4201"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="clerk@brooklynwi.gov"/></p>																									
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p><input type="radio"/> Yes (0 points)</p> <p><input checked="" type="radio"/> No (40 points)</p> <p>If No, please explain:</p> <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">Debt ratio coverage is 109% (page 33 in audit report) should be 110%.</div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?</p> <p>Year: <input style="width: 80px;" type="text" value="2015"/></p> <p><input checked="" type="radio"/> 0-2 years ago (0 points)</p> <p><input type="radio"/> 3 or more years ago (20 points)</p> <p><input type="radio"/> N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWFP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p><input checked="" type="radio"/> Yes (0 points)</p> <p><input type="radio"/> No (40 points)</p>	40																								
REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]																									
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised?</p> <p>Year: <input style="width: 80px;" type="text" value="2015"/></p> <p><input checked="" type="radio"/> 1-2 years ago (0 points)</p> <p><input type="radio"/> 3 or more years ago (20 points)</p> <p><input type="radio"/> N/A</p> <p>If N/A, please explain:</p> <div style="border: 1px solid black; height: 20px; margin-bottom: 5px;"></div> <p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%;"></td> <td style="width: 5%; text-align: right;">\$</td> <td style="width: 30%; text-align: right;"><input style="width: 100%;" type="text" value="271,360.54"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td></td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td></td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="271,360.54"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: center;">+</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="35,819.81"/></td> </tr> <tr> <td>3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)</td> <td style="text-align: center;">-</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="1,866.00"/></td> </tr> <tr> <td>3.2.6 Ending Balance as of December 31st for CMAR Reporting Year</td> <td></td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="305,314.35"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR		\$	<input style="width: 100%;" type="text" value="271,360.54"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)		\$	<input style="width: 100%;" type="text" value="0.00"/>	3.2.3 Adjusted January 1st Beginning Balance		\$	<input style="width: 100%;" type="text" value="271,360.54"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input style="width: 100%;" type="text" value="35,819.81"/>	3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)	-	\$	<input style="width: 100%;" type="text" value="1,866.00"/>	3.2.6 Ending Balance as of December 31st for CMAR Reporting Year		\$	<input style="width: 100%;" type="text" value="305,314.35"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR		\$	<input style="width: 100%;" type="text" value="271,360.54"/>																						
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)		\$	<input style="width: 100%;" type="text" value="0.00"/>																						
3.2.3 Adjusted January 1st Beginning Balance		\$	<input style="width: 100%;" type="text" value="271,360.54"/>																						
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input style="width: 100%;" type="text" value="35,819.81"/>																						
3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)	-	\$	<input style="width: 100%;" type="text" value="1,866.00"/>																						
3.2.6 Ending Balance as of December 31st for CMAR Reporting Year		\$	<input style="width: 100%;" type="text" value="305,314.35"/>																						

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

Replace and update SCADA software Wonder Ware and Sonic Wall (\$1866.00).

3.3 What amount should be in your Replacement Fund? \$ 305,314.55

Please note: If you had a CWFP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the HELP link under Info in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Phosphorus compliance planning, currently underway, will determine the need for any capital upgrades in the specified timeframe. In the preliminary compliance alternatives plan, capital costs are projected to be approximately \$0.5 million to implement biological and chemical phosphorus removal within the next five to ten years. There would be additional annual expenditures for increased O&M and for water quality trading.	0	

5. Financial Management General Comments

Rate structure will be analyzed for debt ratio coverage to be in compliance.

Total Points Generated	40
Score (100 - Total Points Generated)	60
Section Grade	F

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Sanitary Sewer Collection Systems

1. CMOM Program

1.1 Do you have a Capacity, Management, Operation & Maintenance (CMOM) requirement in your WPDES permit?

Yes

No

1.2 Did you have a documented (written records/files, computer files, video tapes, etc.) sanitary sewer collection system operation & maintenance (O&M) or CMOM program last calendar year?

Yes (Continue with question 1)

No (30 points) (Go to question 2)

1.3 Check the elements listed below that are included in your O&M or CMOM program.

Goals

Describe the specific goals you have for your collection system:

Organization

Do you have the following written organizational elements (check only those that apply)?

Ownership and governing body description

Organizational chart

Personnel and position descriptions

Internal communication procedures

Public information and education program

Legal Authority

Do you have the legal authority for the following (check only those that apply)?

Sewer use ordinance Last Revised Date (MM/DD/YYYY)

Pretreatment/industrial control Programs

Fat, oil and grease control

Illicit discharges (commercial, industrial)

Private property clear water (sump pumps, roof or foundation drains, etc.)

Private lateral inspections/repairs

Service and management agreements

Maintenance Activities (provide details in question 2)

Design and Performance Provisions

How do you ensure that your sewer system is designed and constructed properly?

State plumbing code

DNR NR 110 standards

Local municipal code requirements

Construction, inspection, and testing

Others:

Overflow Emergency Response Plan:

Does your emergency response capability include (check only those that apply)?

Alarm system and routine testing

Emergency equipment

Emergency procedures

Communications/notifications (DNR, internal, public, media, etc.)

Capacity Assurance:

How well do you know your sewer system? Do you have the following?

Current and up-to-date sewer map

Sewer system plans and specifications

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

<input checked="" type="checkbox"/> Manhole location map <input checked="" type="checkbox"/> Lift station pump and wet well capacity information <input checked="" type="checkbox"/> Lift station O&M manuals Within your sewer system have you identified the following? <input type="checkbox"/> Areas with flat sewers <input type="checkbox"/> Areas with surcharging <input type="checkbox"/> Areas with bottlenecks or constrictions <input type="checkbox"/> Areas with chronic basement backups or SSOs <input type="checkbox"/> Areas with excess debris, solids, or grease accumulation <input checked="" type="checkbox"/> Areas with heavy root growth <input checked="" type="checkbox"/> Areas with excessive infiltration/inflow (I/I) <input type="checkbox"/> Sewers with severe defects that affect flow capacity <input type="checkbox"/> Adequacy of capacity for new connections <input checked="" type="checkbox"/> Lift station capacity and/or pumping problems <input checked="" type="checkbox"/> Annual Self-Auditing of your O&M/CMOM Program to ensure above components are being implemented, evaluated, and re-prioritized as needed <input type="checkbox"/> Special Studies Last Year (check only those that apply): <input type="checkbox"/> Infiltration/Inflow (I/I) Analysis <input type="checkbox"/> Sewer System Evaluation Survey (SSES) <input type="checkbox"/> Sewer Evaluation and Capacity Management Plan (SECAP) <input checked="" type="checkbox"/> Lift Station Evaluation Report <input type="checkbox"/> Others: <div style="border: 1px solid black; height: 20px; width: 100%; margin-top: 5px;"></div>	0
---	---

2. Operation and Maintenance 2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.		
Cleaning	<input style="width: 80%;" type="text" value="100"/>	% of system/year
Root removal	<input style="width: 80%;" type="text" value="20"/>	% of system/year
Flow monitoring	<input style="width: 80%;" type="text" value="100"/>	% of system/year
Smoke testing	<input style="width: 80%;" type="text" value="0"/>	% of system/year
Sewer line televising	<input style="width: 80%;" type="text" value="0"/>	% of system/year
Manhole inspections	<input style="width: 80%;" type="text" value="100"/>	% of system/year
Lift station O&M	<input style="width: 80%;" type="text" value="3"/>	# per L.S./year
Manhole rehabilitation	<input style="width: 80%;" type="text" value="0"/>	% of manholes rehabbed
Mainline rehabilitation	<input style="width: 80%;" type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input style="width: 80%;" type="text" value="0"/>	% of system/year
Private sewer I/I removal	<input style="width: 80%;" type="text" value="0"/>	% of private services
Please include additional comments about your sanitary sewer collection system below:		
<div style="border: 1px solid black; height: 20px; width: 100%;"></div>		

3. Performance Indicators 3.1 Provide the following collection system and flow information for the past year.	
---	--

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

36.5	Total actual amount of precipitation last year in inches
34.75	Annual average precipitation (for your location)
7.26	Miles of sanitary sewer
3	Number of lift stations
5	Number of lift station failures
0	Number of sewer pipe failures
0	Number of basement backup occurrences
0	Number of complaints
.065	Average daily flow in MGD (if available)
.072	Peak monthly flow in MGD (if available)
	Peak hourly flow in MGD (if available)
3.2 Performance ratios for the past year:	
1.67	Lift station failures (failures/year)
0.00	Sewer pipe failures (pipe failures/sewer mile/yr)
0.00	Sanitary sewer overflows (number/sewer mile/yr)
0.00	Basement backups (number/sewer mile)
0.00	Complaints (number/sewer mile)
1.1	Peaking factor ratio (Peak Monthly: Annual Daily Avg)
0.0	Peaking factor ratio (Peak Hourly: Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **				
Date	Location	Cause	Estimated Volume (MG)	
None reported				

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

Yes

No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

Yes

No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

Nothing we have very little I/I.

5.4 What is being done to address infiltration/inflow in your collection system?

We have very little.

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Grading Summary

WPDES No: 0023485

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	B	3	10	30
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	D	1	3	3
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	F	0	1	0
Collection	A	4	3	12
TOTALS			37	125
GRADE POINT AVERAGE (GPA) = 3.38				

Notes:

A = Voluntary Range (Response Optional)

B = Voluntary Range (Response Optional)

C = Recommendation Range (Response Required)

D = Action Range (Response Required)

F = Action Range (Response Required)

Compliance Maintenance Annual Report

Brooklyn Wastewater Treatment Facility

Last Updated: Reporting For:
5/19/2016 2015

Resolution or Owner's Statement

Name of Governing

Body or Owner:

The Village of Brooklyn

Date of Resolution or

Action Taken:

5-23-2016

Resolution Number:

2016-04

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = B

During the cold weather months and low flows at are plant it can be struggle to run. We have been working with our engineer Strand and Aqu Fix with possible causes and solutions. We are pretty much 99% residential waste and when small amount of toxic are dumped on us this may be causing our up sets. We have had some very high influent BOD/SS samples. We have reached out and started public education.

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = D

Phosphorus compliance planning, currently underway, will determine the need for any capital upgrades in the specified timeframe. In the preliminary compliance alternatives plan, capital costs are projected to be approximately \$0.5 million to implement biological and chemical phosphorus removal within the next five to ten years.

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = F

Rate structure will be analyzed for debt ratio coverage to be in compliance.

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.38